

SUBMITTAL RECORD _____
JOB _____
LOCATION _____
SUBMITTED TO _____
SUBMITTAL PREPARED BY _____
APPROVED BY _____
DATE _____



Submittal Form CCASA-WFTC Carb Compliant Insulation Adhesive

DESCRIPTION

Duct liner is typically attached to duct walls by two fastening methods; one with mechanical fasteners and the other with adhesive. Mechanical fasteners are utilized to prevent delamination of the liner while adhesives bond the liner to the metal ensuring that air flow can not intrude between the two materials. The choice of an adhesive is affected by several factors some of which are; the method of application, acceptable dry time, solvent type.

Duro Dyne CCASA-WFTC is a high performance aerosol adhesive offering rapid setting and quick dry time. CCASA-WFTC is formulated to tack immediately, fully cure & dry clear within 15 minutes. This adhesive is ideal for use on duct liner, duct wrap or on sheet metal, and is also suitable to bond a variety of substrates. It is suitable in high temperatures environments, as well as where a clear, flexible, or water resistant bond is desired.

FEATURES

- Carb compliant formula
- Convenient spray can
- Rapid Setting
- Quick dry time
- Solvent based

TYPICAL PROPERTIES

Type: Web spray adhesive

Solids: 23%

Weight: 12 oz. net

Propellant: DME & Hydrocarbon blend

Color: White

Odor: Strong solvent

VOC: 38.30%

Evaporation Rate: 30-45 seconds

Bond time: 1 minute - 1 hour

Heat resistance: 120° F maximum

Method of Application: Aerosol spray

Solvent system: heptane, acetone, methyl acetate, oxsol
100/PCBTF



RELATED SMACNA RECOMMENDATIONS*

7.4 Installation Standards For Rectangular Ducts Using Flexible Liner

S2.3 Each layer of duct liner shall be attached with 90 percent coverage of adhesive at the liner contact surface area.

S2.4 All transversely oriented edges of liner not receiving metal nosing shall be coated with adhesive. Liner shall be neatly butted without gaps at transverse joints and shall be coated with adhesive at such joints before butting.

S2.6 Ducts with interior widths of 8 in. (203 mm) or less do not require mechanical fasteners in addition to adhesive.

**From SMACNA HVAC Duct Construction Standards Metal and Flexible • Third Edition • 2005*

CCASA-WFTC cans are designed to be in accordance with the RCRA, so they are empty when there is no further contents. According to federal regulations, these cans can go into the regular waste except when located in a jurisdiction that does not allow empty aerosols.

ITEM#	CODE	DESCRIPTION
5164	CCASA-WFTC	Carb Compliant Insulation Adhesive

SUGGESTED SPECIFICATIONS

All metal duct shall be lined according to SMACNA HVAC Duct Construction Standards. Each layer of duct liner shall be attached with 90% coverage of adhesive at the liner contact surface area. Adhesive shall be a solvent base aerosol. Adhesive shall be CCASA-WFTC Carb Compliant Insulation Adhesive, code CCASA-WFTC, as manufactured by Duro Dyne Corporation.

Duro Dyne Corporate Headquarters, Bay Shore, NY
631-249-9000 • Fax: 631-249-8346
Duro Dyne Midwest • Duro Dyne West • Duro Dyne Canada
www.durodyne.com • E-mail: durodyne@durodyne.com



©2019 DURO DYNE CORP.
Printed in the USA 10/19
BO005440