

SUBMITTAL RECORD**JOB** _____**LOCATION** _____**SUBMITTED TO** _____**SUBMITTAL PREPARED BY** _____**APPROVED BY** _____**DATE** _____**DESCRIPTION**

The Dyna-Stud is a heavy duty grade 5 hex head bolt with one end of a super strong aircraft rated cable attached. The bolt is threaded into the expansion anchor without putting stress on the cable. This makes for a much safer and tighter connection. The other end of the cable, in conjunction with the cable lock, is used to attach the object being supported.

ORDERING INFORMATION

Item #	Code	Description	Safe Working Load*
30075	SDSA3805ZC	3/8 Swaged Threaded Stud x 5ft Dyna-Stud Cable Assembly with Zip-Clip	25-220 lbs. (12-100 kg)
30076	SDSA3810ZC	3/8 Swaged Threaded Stud x 10ft Dyna-Stud Cable Assembly with Zip-Clip	25-220 lbs. (12-100 kg)
30077	SDSA3815ZC	3/8 Swaged Threaded Stud x 15ft Dyna-Stud Cable Assembly with Zip-Clip	25-220 lbs. (12-100 kg)
30078	SDSA3825ZC	3/8 Swaged Threaded Stud x 25ft Dyna-Stud Cable Assembly with Zip-Clip	25-220 lbs. (12-100 kg)
3/8" drop in sold separately.			
Item # 30075 - 30078 come with Zip-Clip Cable Lock.			
*Safe Working Loads are based on a 5:1 Safety Factor			

WARNINGS

ALWAYS CONFIRM ENGAGEMENT OF CABLE LOCK ON WIRE BEFORE APPLYING THE LOAD.

PULL ADJUSTMENT PIN BACK AND PASS WIRE ROPE THROUGH DYNA-TITE CABLE LOCK: Failure to pull adjustment pin first may cause damage to serrated teeth and reduce holding capacity.

TO ENSURE HANGING SYSTEM INTEGRITY AND SAFETY: USE ONLY DURO DYNE WIRE ROPE SUPPLIED IN SET.

WORKING LOAD LIMIT (WLL) MUST FALL WITHIN THE STATED WORKING LOAD RANGE OF THE CABLE LOCK: Each product is load rated and incorporates a minimum safety factor of 5:1. This WLL takes into account the specification criteria of the Dyna-Tite Cable Lock and the wire rope.

DO NOT USE ON COATED WIRE ROPE: It is important to maintain the metal to metal contact between the locking pawls in the Dyna-Tite and the wire rope.

DO NOT APPLY PAINT OR OTHER COATING: to any part of the assembly as these may impair the free movement of the locking pawls inside the Dyna-Tite Cable Lock.

DO NOT APPLY LUBRICANT: to any part of the assembly as this will alter the surface nature of the wire rope and attract dirt and debris.

DO NOT USE FOR LIFTING: (Under Hook slings) This product is designed for static load applications only.

KEEP THE PRODUCT CLEAN AND FREE FROM DIRT: Any dirt should be removed from the product prior to assembly.

INSPECT PERIODICALLY: Upon inspection, discard and replace if worn, distorted, or damaged.

REMOVE DAMAGED WIRE ENDS: Using a designated pair of wire rope cutters prior to inserting into the Dyna-Tite Cable Lock.

FOR DRY LOCATIONS ONLY

DO NOT USE IN CHLORINATED ATMOSPHERES

Please see our Dyna-Tite testing and warnings webpage
for the most detailed list of warnings:
<http://www.durodyne.com/DTTesting.php>

**DURO
DYNE****Dyna-Tite**

Submittal Form

Swaged Dyna-Stud®

Threaded Stud with Zip-Clip

**SUGGESTED SPECIFICATION**

All ductwork and equipment shall be supported using wire rope cable terminated by Cable Locks. All Cable Locks shall have an Ultimate Breaking Strength (U.B.S.) of at least 5 times the published Working Load Limit (W.L.L.). Wire ropes shall be of the size and spaced per manufacturers printed specifications. Wire Rope and Cable Locks shall be as supplied by Duro Dyne Corporation.

SPECIFICATION DATA

- 1) All wire rope supplied by Duro Dyne is statistically tested to minimum breaking strength.
- 2) Dyna-Tite Suspension System has been submitted and tested to be an acceptable alternative to the duct hanger systems prescribed in SMACNA HVAC-DCS 2nd edition By SMACNA Testing & Research Institute.
- 3) All Working Load Ratings of Dyna-Tite Cable Locks manufactured by Duro Dyne have been witnessed and verified by Independent Testing Labs.
- 4) Dyna-Tite Cable Locks may be used in temperatures up to 300 degrees F.
- 5) Dyna-Tite Cable Locks wedges are constructed of corrosion resistant sintered steel.
- 6) Dyna-Tite Cable Lock springs are constructed of tempered stainless steel.

WIRE ROPE SPECIFICATION

CARBON STEEL & GALVANIZED

Galvanized steel wire rope, supplied by Duro Dyne is manufactured to exacting standards and statistically tested to verify the breaking strength. Duro Dyne recommends only using wire rope supplied by Duro Dyne.

APPLICABLE SMACNA STANDARD**4.2.11 Hanging System Selection**

The selection of a hanging system should not be taken lightly not only because it involves a significant portion of the erection labor, but also because an inadequate hanging system can be disastrous. In any multiple hanging system, the failure of one hanger transfers that load to adjacent hangers. If one of these fail, an even greater load is transferred to the next. The result is a cascading failure in which an entire run of duct might fail.

There are many hanger alternatives, especially in the upper attachments. Besides structural adequacy, the contractor's choice of hanging system must also take into account the particulars of the building structure, the skills of the workmen, the availability of tooling, and the recommendations of the fastener manufacturer. Because of these variables, it is suggested that the hanging system be the contractor's choice, subject to the approval of the mechanical engineer.

Duro Dyne East Division, Bay Shore, NY
Duro Dyne Midwest Division, Hamilton, OH
Duro Dyne West Division, Fontana, CA
Duro Dyne Canada, Lachine, Quebec, Canada

www.durodyne.com E-mail: durodyne@durodyne.com

631-249-9000 Fax: 631-249-8346
513-870-6000 Fax: 513-870-6005
562-926-1774 Fax: 562-926-5778
514-422-9760 Fax: 514-636-0328

**DURO
DYNE**

©2015 Duro Dyne Corporation
Printed in USA 07/17
B0030425